

# Central Utah Water Conservancy District

## CROSS CONNECTION CONTROL POLICY

A policy related to “cross connection control and backflow-prevention control” at Central Utah Water Conservancy District.

### PART I:

#### CROSS CONNECTION CONTROL AND BACKFLOW PREVENTION

(I) It shall be against Central Utah Water Conservancy District policy, at any connection supplied with potable water from the Central Utah Water Conservancy District distribution systems, to do any of the following:

(a) To install or use any physical connection or arrangement of piping or fixtures, which may allow any fluid or substances unsuitable for human consumption to enter the potable water distribution system, as required by Section 608.1 through 608.5 of the 2018 International Plumbing Code as adopted by the State of Utah.

(b) To install any connection, arrangement, or fixtures without a Backflow Prevention Device or approved Assembly unless arranged otherwise by Central Utah Water Conservancy District staff (Cross Connection Control Administrator or Professional Engineer).

(c) To incorrectly install any Backflow Prevention Device or Assembly required by Section 608.6 and 608.1 of the 2018 International Plumbing Code and amendments as adopted by the state of Utah.

(2) Any person or entity found in violation of this policy shall be subject to reprimand or other appropriate disciplinary action as determined by Central Utah Water Conservancy District.

(3) Administration of this policy shall be referenced by “Cross Connection Control Program of Utah, (April 2016). A copy of the manual shall be available at the office of Central Utah Water Conservancy District, 1426 East 750 North Suite 400, Orem Utah 84097.

(4) Each Customer, City or Service Agency connected to Central Utah Water Conservancy District potable water distribution systems shall have a Cross Connection Control Program in place or as required by the State of Utah Division of Drinking Water and will cooperate with Hazard Assessment Investigations.

(5) Backflow prevention assemblies required by the policy will be required to be tested at least annually and shall prepare and maintain a Backflow Assembly Information sheet on all such assemblies and Test results shall be maintained for a period of no less than five (5) years.

PART II:

This policy shall take effect on August 1, 2020, A copy of the policy shall be placed in the office of Central Utah Water Conservancy District system binder and will be reviewed for all new construction projects on a case by case basis.

Signed:   
Gene Shawcroft

Date 7/30/2020

Title: General Manager